

May 10, 2019

Illinois Environmental Protection Agency
Bureau of Water
Compliance Assurance Section, Mail Code #19
1021 North Grand Avenue East
Springfield, Illinois 62794-9276

Illinois Environmental Protection Agency
DWPC Marion Region
2309 West Main Street
Marion, Illinois 62959

Discharge Monitoring Report for April 2019
(Permit No. 2015-EP-59681-1)
Pump and Treat System
Crab Orchard National Wildlife Refuge, Marion, Illinois

Dear Sir or Madam:

AECOM, on behalf of the United States Fish and Wildlife Service (USFWS), is submitting the attached April 2019 Discharge Monitoring Report (DMR) for the subject treatment system located on the Crab Orchard National Wildlife Refuge (CONWR) in Marion, Illinois. This DMR has been prepared as required by the Permit to Construct, Own, and Operate (Permit No. 2015-EP-59681-1), dated April 28, 2017, for discharge to the City of Marion, IL publicly owned treatment works (POTW). Discharge of the treated effluent of the Pump and Treat System to the Marion POTW commenced on May 4, 2011. For the month of April 2019, the system operated the full duration of the month. The enclosed discharge summary was used to prepare the DMR.

Due to an error in Excel, the "totalizer" values of the Discharge Summary were reported using the system's current totalizer. In 2014, the system's totalizer was removed and replaced after approximately 5 million gallons had been discharged. Beginning with the October 2018 Discharge Summary, these additional gallons discharged were not accounted for and reflected in the spreadsheet. This error has been corrected and the Discharge Summary reflects total gallons discharged from the system since it was initially started. Please note this error is only on the Discharge Summary (page 3 of the DMR package) and does not affect the DMR (page 2 of the DMR package).

Please contact Mr. Andy Day (314.429.0100) with any questions.

Sincerely,



Andy Day
Environmental Scientist
AECOM

encl: DMR
Discharge Summary

cc: *(via electronic mail)*
Viral Patel, USFWS
Paul Lake, IEPA
Mike Coffey, USFWS Project Coordinator
Chuck Beasley, USFWS
Brent Cain, City of Marion POTW

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

Form Approved

OMB No. 2040-0004

NAME USFWS
Crab Orchard National Wildlife
Refuge
ADDRESS 8588 Route 148
Marion, IL 62599

DISCHARGE MONITORING REPORT (DMR)


2015-EP-59681-1	to POTW
PERMIT NUMBER	DISCHARGE NUMBER

FACILITY Crab Orchard National Wildlife
LOCATION Refuge Superfund Site

MONITORING PERIOD									
FROM		YEAR	MO	DAY	TO		YEAR	MO	DAY
		2019	04	01			2019	04	30

NOTE: Read instructions before

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Flow, Total Daily Volume	SAMPLE	5,639	5,991	gpd					0	Daily	Cont
	PERMIT REQUIREMENT	7,200	14,400							Daily	Cont
Flow, Daily Average Rate	SAMPLE	3.9	4.2	gpm					0	Daily	Cont
	PERMIT REQUIREMENT	Report	Report							Daily	Cont
pH, Standard Units	SAMPLE				7.15		7.15	s.u.	0	1/mo	Grab
	PERMIT REQUIREMENT				5.5		9.5			1/mo	Grab
Polychlorinated Biphenyls, total	SAMPLE				<0.00042	<0.00042	<0.00042	mg/L	0	1/mo	Grab
	PERMIT REQUIREMENT						0.003			1/mo	Grab
	SAMPLE										
	PERMIT REQUIREMENT										
	SAMPLE										
	PERMIT REQUIREMENT										
	SAMPLE										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		TELEPHONE		DATE		
Andrew T. Day			314	802.1141	2019	05	10
TYPED OR PRINTED			AREA	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

Operated under the supervision of Andrew Day and Brooks Pfeiffer, Class K Operators - Crab Orchard Pump and Treat System

Crab Orchard National Wildlife Refuge
Permanent Pump and Treat System
Discharge Summary - April 2019
AECOM Project Number: 60582889

April 2019	Flow (gpm)	Totalizer (gal)	Total Flow (gpd)	Effluent		Comments
				Total PCBs (mg/L)	pH (s.u.)	
04/01/19	3.60	12,801,290	5,171			
04/02/19	3.60	12,806,461	5,178			
04/03/19	3.60	12,811,639	5,154			
04/04/19	3.59	12,816,793	5,158			
04/05/19	3.58	12,821,951	5,149			
04/06/19	3.58	12,827,100	5,137			
04/07/19	3.50	12,832,237	4,981			
04/08/19	3.57	12,837,218	5,217			
04/09/19	3.70	12,842,435	5,351			
04/10/19	3.70	12,847,786	5,344			
04/11/19	3.70	12,853,130	5,333			
04/12/19	3.79	12,858,463	5,473	< 0.00042	7.15	
04/13/19	4.05	12,863,936	5,851			
04/14/19	4.17	12,869,787	5,991			
04/15/19	4.15	12,875,778	5,976			
04/16/19	4.12	12,881,754	5,965			
04/17/19	4.15	12,887,719	5,976			
04/18/19	4.13	12,893,695	5,965			
04/19/19	4.11	12,899,660	5,936			
04/20/19	4.10	12,905,596	5,922			
04/21/19	4.10	12,911,518	5,921			
04/22/19	4.10	12,917,439	5,902			
04/23/19	4.10	12,923,341	5,897			
04/24/19	4.10	12,929,238	5,895			
04/25/19	4.10	12,935,133	5,902			
04/26/19	4.10	12,941,035	5,897			
04/27/19	4.10	12,946,932	5,894			
04/28/19	4.10	12,952,826	5,887			
04/29/19	4.10	12,958,713	5,879			
04/30/19	4.09	12,964,592	5,857			
Data Summary	Flow (gpm)	Totalizer (gal)	Total Flow (gpd)	Effluent		Comments
				Total PCBs (mg/L)	pH (s.u.)	
Minimum	3.6	12,801,290	4,981	< 0.00042	7.15	
Average	3.9	12,880,507	5,639	< 0.00042	7.15	
Maximum	4.2	12,964,592	5,991	< 0.00042	7.15	

Notes:
gpm - gallons per minute
gal - gallons
gpd - gallons per day
PCBs - polychlorinated biphenyls
mg/L - milligrams per liter
< - analyte not detected
s.u. - standard units